

Environmental Protection Agency

Pt. 63, Subpt. GGG, Table 7

Item of equipment	Control requirement ^a
Manhole ^b	(c) Water seal with submerged discharge or barrier to protect discharge from wind. (a) TFSC; or (b) TSFC with a vent to either a process or to a control device meeting the requirements of § 63.1256(h)(2); or (c) If the item is vented to the atmosphere, use a TFSC with a properly operating water seal at the entrance or exit to the item to restrict ventilation in the collection system. The vent pipe shall be at least 90 cm in length and not exceeding 10.2 cm in nominal inside diameter.
Lift station	(a) TFSC; or (b) TFSC with a vent to either a process or to a control device meeting the requirements of § 63.1256(h)(2); or (c) If the lift station is vented to the atmosphere, use a TFSC with a properly operating water seal at the entrance or exit to the item to restrict ventilation in the collection system. The vent pipe shall be at least 90 cm in length and not exceeding 10.2 cm in nominal inside diameter. The lift station shall be level controlled to minimize changes in the liquid level.
Trench	(a) TFSC; or (b) TFSC with a vent to either a process or to a control device meeting the requirements of § 63.1256(h)(2); or (c) If the item is vented to the atmosphere, use a TFSC with a properly operating water seal at the entrance or exit to the item to restrict ventilation in the collection system. The vent pipe shall be at least 90 cm in length and not exceeding 10.2 cm in nominal inside diameter.
Pipe	Each pipe shall have no visible gaps in joints, seals, or other emission interfaces.
Oil/Water separator	(a) Equip with a fixed roof and route vapors to a process or equip with a closed-vent system that routes vapors to a control device meeting the requirements of § 63.1256(h)(2); or (b) Equip with a floating roof that meets the equipment specifications of § 60.693(a)(1)(i), (a)(1)(ii), (a)(2), (a)(3), and (a)(4).
Tank	Maintain a fixed roof and consider vents as process vents. ^c

^a Where a tightly fitting solid cover is required, it shall be maintained with no visible gaps or openings, except during periods of sampling, inspection, or maintenance.

^b Manhole includes sumps and other points of access to a conveyance system.

^c A fixed roof may have openings necessary for proper venting of the tank, such as pressure/vacuum vent, j-pipe vent.

[65 FR 52616, Aug. 29, 2000]

TABLE 6 TO SUBPART GGG OF PART 63—WASTEWATER—COMPLIANCE OPTIONS FOR WASTEWATER TANKS

Capacity, m ³	Maximum true vapor pressure, kPa	Control requirements
<75	§ 63.1256(b)(1).
>75 and <151	<13.1	§ 63.1256(b)(1).
.....	>13.1	§ 63.1256(b)(2).
>151	<5.2	§ 63.1256(b)(1).
.....	>5.2	§ 63.1256(b)(2).

TABLE 7 TO SUBPART GGG OF PART 63—WASTEWATER—INSPECTION AND MONITORING REQUIREMENTS FOR WASTE MANAGEMENT UNITS

To comply with	Inspection or monitoring requirement	Frequency of inspection or monitoring	Method
TANKS:			
63.1256(b)(3)(i)	Inspect fixed roof and all openings for leaks.	Initially Semiannually	Visual.
63.1256(b)(4)	Inspect floating roof in accordance with §§ 63.120(a)(2) and (a)(3).	See §§ 63.120(a)(2) and (a)(3).	Visual.
63.1256(b)(5)	Measure floating roof seal gaps in accordance with §§ 63.120(b)(2)(i) through (b)(4).	See § 63.120(b)(2)(i) through (b)(4).
.....	—Primary seal gaps	Initially Once every 5 years (annually if no secondary seal).	
.....	—Secondary seal gaps	Initially Semiannually	
63.1256(b)(7)	Inspect wastewater tank for control equipment failures and improper work practices.	Initially Semiannually	Visual.
63.1256(b)(8)			
SURFACE IMPOUNDMENTS:			